

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 35/2026

Dated: 17.08.26.

It is certified that an inspection team headed by Vidya. M.S. - Health-Inspector (C/c)
 (Name of Officers with designation) from Community Health Centre, Muhannoe
 (Name of Department/ Office) inspected the K.F. Carmel Central School, Muhannoe.
 (Name & Address of the school) on 13/08/26.....(date of inspection) and found that
 the K.F. Carmel Central School.....(Name of school) has safe drinking water facilities
 for the students and members of staff of the institution and is maintaining the hygienic sanitation
 condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.
 The above is valid for a period of 13/08/26 to 13/08/2027 .

Signature with Seal: Vidya

Name

Designation

HEALTH INSPECTOR
COMMUNITY HEALTH CENTRE
MUHANNUE

Name & Address of the Office / Department : Inspector (H & O)

To

Principal
K.F. Carmel Central School, Muhannoe, Aleppo.

(Name & Address of the Institution)

* The filled up certificate should be either in Hindi or English. If it is issued in vernacular language,
 translated notarized version in English be uploaded along with the original vernacular certificate as a
 single pdf.



QUALITY CONTROL SUB DISTRICT LAB
KERALA WATER AUTHORITY
S.L PURAM, KANJIKUZH, ALAPPUZHA

WATER ANALYSIS REPORT

Email: aeqcsdisipuram@gmail.com

Report No: 2026/QCSDL/SLP-868	Date: 25/07/2026
-------------------------------	------------------

Customer Name & Address K E CARMEL CENTRAL SCHOOL MUHAMMA	1.Date of Sample Received	: 23/07/2026
	2.Sampling done by	: H I CHC Muhamma
	3.Sample Code	: 2026/QCSDL/SLP-868
	4.Source of Sample	: Tap water
	5.Sample Quantity	: 200 ml
	6.Test performing dates	From: 24/07/2026 To: 25/07/2026

BACTERIOLOGICAL ANALYSIS

Sl. No	Parameters	Acceptable limits as per – IS 10500 – 2012	Test Method	Result
1	Coliforms/100ml	Shall not be detected/100 ml	IS15185:2016	PRESENT
2	E-coli/100ml	Shall not be detected/100 ml	IS15185:2016	ABSENT

Remarks:-

NB -The results stated above related only to the sample(s) submitted for testing This test Certificate shall not be reproduced except in full without the written approval of the Laboratory.

Test Method:
Coliform - Membrane Filtration Method
E- Coli- Membrane Filtration Method



NOL
Verified & Authorized by
Bacteriologist

End of the report

Page 1